

# Certificate of Product Ratings

**AHRI Certified Reference Number: 8028388**

**Date: 3/20/2015**

**Product: Variable Speed Mini-Split Air-Conditioner, with Remote Outdoor Unit-Air-Source, Free Delivery**

**Outdoor Unit Model Number: BIN312C1V32**

**Indoor Unit Model Number: BIN312C1V32**

**Manufacturer: INNOVAIR CORPORATION**

**Trade/Brand name: BIO-INVERTER**

**Series name:**

**Manufacturer responsible for the rating of this system combination is INNOVAIR CORPORATION**

**Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:**

Cooling Capacity (Btuh): 9000

EER Rating (Cooling): 9.00

SEER Rating (Cooling): 15.00

FootNote 11 - The AHRI 210/240 certified EER ratings are calculated under the same methodology as the EER ratings at T1 conditions of ISO 5151:2010 and ISO 13253:2011.

www.ahridirectory.org

CERTIFIED RATINGS FOR VARIABLE-SPEED, MINI- AND MULTI-SPLIT SYSTEMS ARE VALID FOR ALL COMBINATIONS OF INDOOR UNITS (BASED ON COMBINATION TYPES) WITH THE SPECIFIC OUTDOOR UNIT LISTED ABOVE AND IN THE AHRI DIRECTORY OF CERTIFIED EQUIPMENT. VISIT WWW.AHRIDIRECTORY.ORG TO VERIFY THAT THIS COMBINATION IS AN ACTIVE LISTING AND THE DATA LISTED ON THIS CERTIFICATE IS ACCURATE. SEARCH ON THE AHRI REFERENCE # TO QUICKLY LOCATE THIS COMBINATION IN THE DIRECTORY.

\* Ratings followed by an asterisk (\*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

**CERTIFICATE NO.:** 130713777625951281

# Certificate of Product Ratings

**AHRI Certified Reference Number: 8028389**

**Date: 3/20/2015**

**Product: Variable Speed Mini-Split Air-Conditioner, with Remote Outdoor Unit-Air-Source, Free Delivery**

**Outdoor Unit Model Number: BIN414C1V32**

**Indoor Unit Model Number: BIN414C1V32**

**Manufacturer: INNOVAIR CORPORATION**

**Trade/Brand name: BIO-INVERTER**

**Series name:**

**Manufacturer responsible for the rating of this system combination is INNOVAIR CORPORATION**

**Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:**

Cooling Capacity (Btuh): 12000

EER Rating (Cooling): 9.00

SEER Rating (Cooling): 15.00

FootNote 11 - The AHRI 210/240 certified EER ratings are calculated under the same methodology as the EER ratings at T1 conditions of ISO 5151:2010 and ISO 13253:2011.

www.ahridirectory.org

CERTIFIED RATINGS FOR VARIABLE-SPEED, MINI- AND MULTI-SPLIT SYSTEMS ARE VALID FOR ALL COMBINATIONS OF INDOOR UNITS (BASED ON COMBINATION TYPES) WITH THE SPECIFIC OUTDOOR UNIT LISTED ABOVE AND IN THE AHRI DIRECTORY OF CERTIFIED EQUIPMENT. VISIT WWW.AHRIDIRECTORY.ORG TO VERIFY THAT THIS COMBINATION IS AN ACTIVE LISTING AND THE DATA LISTED ON THIS CERTIFICATE IS ACCURATE. SEARCH ON THE AHRI REFERENCE # TO QUICKLY LOCATE THIS COMBINATION IN THE DIRECTORY.

\* Ratings followed by an asterisk (\*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

**CERTIFICATE NO.:** 130713778335920934

# Certificate of Product Ratings

**AHRI Certified Reference Number: 6087019**

**Date: 5/28/2013**

**Product: Variable Speed Mini-Split Air-Conditioner, with Remote Outdoor Unit-Air-Source, Free Delivery**

**Outdoor Unit Model Number: BIN414C2V32**

**Indoor Unit Model Number: BIN414C2V32**

**Manufacturer: INNOVAIR CORPORATION**

**Trade/Brand name: BIO-INVERTER**


**Manufacturer responsible for the rating of this system combination is INNOVAIR CORPORATION**

**Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:**

Cooling Capacity (Btuh): 12000

EER Rating (Cooling): 9.00

SEER Rating (Cooling): 15.00



CERTIFIED RATINGS FOR VARIABLE-SPEED, MINI- AND MULTI-SPLIT SYSTEMS ARE VALID FOR ALL COMBINATIONS OF INDOOR UNITS (BASED ON COMBINATION TYPES) WITH THE SPECIFIC OUTDOOR UNIT LISTED ABOVE AND IN THE AHRI DIRECTORY OF CERTIFIED EQUIPMENT. VISIT [WWW.AHRIDIRECTORY.ORG](http://WWW.AHRIDIRECTORY.ORG) TO VERIFY THAT THIS COMBINATION IS AN ACTIVE LISTING AND THE DATA LISTED ON THIS CERTIFICATE IS ACCURATE. SEARCH ON THE AHRI REFERENCE # TO QUICKLY LOCATE THIS COMBINATION IN THE DIRECTORY.

\* Ratings followed by an asterisk (\*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed below.



# Certificate of Product Ratings

**AHRI Certified Reference Number: 6087020**

**Date: 5/28/2013**

**Product: Variable Speed Mini-Split Air-Conditioner, with Remote Outdoor Unit-Air-Source, Free Delivery**

**Outdoor Unit Model Number: BIN520C2V32**

**Indoor Unit Model Number: BIN520C2V32**

**Manufacturer: INNOVAIR CORPORATION**

**Trade/Brand name: BIO-INVERTER**


**Manufacturer responsible for the rating of this system combination is INNOVAIR CORPORATION**

**Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:**

Cooling Capacity (Btuh): 18000

EER Rating (Cooling): 9.00

SEER Rating (Cooling): 15.00



CERTIFIED RATINGS FOR VARIABLE-SPEED, MINI- AND MULTI-SPLIT SYSTEMS ARE VALID FOR ALL COMBINATIONS OF INDOOR UNITS (BASED ON COMBINATION TYPES) WITH THE SPECIFIC OUTDOOR UNIT LISTED ABOVE AND IN THE AHRI DIRECTORY OF CERTIFIED EQUIPMENT. VISIT [WWW.AHRIDIRECTORY.ORG](http://WWW.AHRIDIRECTORY.ORG) TO VERIFY THAT THIS COMBINATION IS AN ACTIVE LISTING AND THE DATA LISTED ON THIS CERTIFICATE IS ACCURATE. SEARCH ON THE AHRI REFERENCE # TO QUICKLY LOCATE THIS COMBINATION IN THE DIRECTORY.

\* Ratings followed by an asterisk (\*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed below.



# Certificate of Product Ratings

**AHRI Certified Reference Number: 6087021**

**Date: 5/28/2013**

**Product: Variable Speed Mini-Split Air-Conditioner, with Remote Outdoor Unit-Air-Source, Free Delivery**

**Outdoor Unit Model Number: BIN625C2V32**

**Indoor Unit Model Number: BIN625C2V32**

**Manufacturer: INNOVAIR CORPORATION**

**Trade/Brand name: BIO-INVERTER**


**Manufacturer responsible for the rating of this system combination is INNOVAIR CORPORATION**

**Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:**

Cooling Capacity (Btuh): 22000

EER Rating (Cooling): 9.00

SEER Rating (Cooling): 15.00



CERTIFIED RATINGS FOR VARIABLE-SPEED, MINI- AND MULTI-SPLIT SYSTEMS ARE VALID FOR ALL COMBINATIONS OF INDOOR UNITS (BASED ON COMBINATION TYPES) WITH THE SPECIFIC OUTDOOR UNIT LISTED ABOVE AND IN THE AHRI DIRECTORY OF CERTIFIED EQUIPMENT. VISIT [WWW.AHRIDIRECTORY.ORG](http://WWW.AHRIDIRECTORY.ORG) TO VERIFY THAT THIS COMBINATION IS AN ACTIVE LISTING AND THE DATA LISTED ON THIS CERTIFICATE IS ACCURATE. SEARCH ON THE AHRI REFERENCE # TO QUICKLY LOCATE THIS COMBINATION IN THE DIRECTORY.

\* Ratings followed by an asterisk (\*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed below.

