

Certificate of Product Ratings

AHRI Certified Reference Number : 202053797

Date : 06-04-2018

Model Status : Active

AHRI Type : HMSV-A-CB

Outdoor Unit Brand Name : INNOVAIR

Outdoor Unit Model Number : VOM0522H7RE602

Indoor Type : Non-Ducted Indoor Units

Rated as follows in accordance with the latest edition of ANSI/AHRI 210/240 with Addenda 1 and 2, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (95F) : 18000

EER (95F) : 12.50

SEER : 22.00

High Heat (47F) : 19000

Low Heat (17F) : 12800

HSPF : 11.00

Sold in? : USA

AHRI CERTIFIED®
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.
Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2018 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

131725940554250659

Certificate of Product Ratings

AHRI Certified Reference Number : 202053798

Date : 06-04-2018

Model Status : Active

AHRI Type : HMSV-A-CB

Outdoor Unit Brand Name : INNOVAIR

Outdoor Unit Model Number : VOM0733H7RE603

Indoor Type : Non-Ducted Indoor Units

Rated as follows in accordance with the latest edition of ANSI/AHRI 210/240 with Addenda 1 and 2, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (95F) : 24000

EER (95F) : 12.50

SEER : 21.00

High Heat (47F) : 26000

Low Heat (17F) : 16600

HSPF : 11.00

Sold in? : USA, Canada

AHRI CERTIFIED®
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.
Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2018 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

131725943803796939



This combination qualifies for a Federal Energy Efficiency tax Credit when placed in service between Feb 17,2009 and Dec 31, 2016.

Certificate of Product Ratings

AHRI Certified Reference Number : 202053799

Date : 06-04-2018

Model Status : Active

AHRI Type : HMSV-A-CB

Outdoor Unit Brand Name : INNOVAIR

Outdoor Unit Model Number : VOM0833H7RE604

Indoor Type : Non-Ducted Indoor Units

Rated as follows in accordance with the latest edition of ANSI/AHRI 210/240 with Addenda 1 and 2, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (95F) : 28400

EER (95F) : 12.50

SEER : 21.00

High Heat (47F) : 30000

Low Heat (17F) : 18000

HSPF : 11.50

Sold in? : USA



†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.
Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2018 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

131725947586172315

Certificate of Product Ratings

AHRI Certified Reference Number : 202053800

Date : 06-04-2018

Model Status : Active

AHRI Type : HMSV-A-CB

Outdoor Unit Brand Name : INNOVAIR

Outdoor Unit Model Number : VOM0836H7RE605

Indoor Type : Non-Ducted Indoor Units

Rated as follows in accordance with the latest edition of ANSI/AHRI 210/240 with Addenda 1 and 2, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (95F) : 34000

EER (95F) : 12.50

SEER : 21.00

High Heat (47F) : 42500

Low Heat (17F) : 20000

HSPF : 11.50

Sold in? : USA

AHRI CERTIFIED[®]
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced. "Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.
Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2018 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

131725948546024405

Certificate of Product Ratings

AHRI Certified Reference Number : 202053801

Date : 06-04-2018

Model Status : Active

AHRI Type : HMSV-A-CB

Outdoor Unit Brand Name : INNOVAIR

Outdoor Unit Model Number : VOM0847H7RE605

Indoor Type : Non-Ducted Indoor Units

Rated as follows in accordance with the latest edition of ANSI/AHRI 210/240 with Addenda 1 and 2, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (95F) : 39000

EER (95F) : 10.40

SEER : 21.00

High Heat (47F) : 45000

Low Heat (17F) : 29000

HSPF : 10.20

Sold in? : USA

AHRI CERTIFIED®
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.
Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2018 Air-Conditioning, Heating, and Refrigeration Institute

AHRI
AIR-CONDITIONING, HEATING,
& REFRIGERATION INSTITUTE

we make life better™

CERTIFICATE NO.:

131725948079770222

Certificate of Product Ratings

AHRI Certified Reference Number: 8778447

Date: 2/23/2016

Product: Variable Speed Multi-Split Heat Pump

Outdoor Unit Model Number: VOM0355H2RE508

Indoor Unit Type: Ducted Indoor Units

Manufacturer: INNOVAIR CORPORATION

Trade/Brand name: INNOVAIR

Series name:

Manufacturer responsible for the rating of this system combination is INNOVAIR CORPORATION

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh): 48500

EER Rating (Cooling): 8.80

SEER Rating (Cooling): 15.50

Heating Capacity(Btuh) @ 47 F: 54500

Region IV HSPF Rating (Heating): 8.20

Heating Capacity(Btuh) @ 17 F: 32600

AHRI CERTIFIED®
www.ahridirectory.org

CERTIFIED RATINGS FOR VARIABLE-SPEED, MINI- AND MULTI-SPLIT SYSTEMS ARE VALID FOR ALL COMBINATIONS OF INDOOR UNITS (BASED ON COMBINATION TYPES) WITH THE SPECIFIC OUTDOOR UNIT LISTED ABOVE AND IN THE AHRI DIRECTORY OF CERTIFIED EQUIPMENT. VISIT WWW.AHRIDIRECTORY.ORG TO VERIFY THAT THIS COMBINATION IS AN ACTIVE LISTING AND THE DATA LISTED ON THIS CERTIFICATE IS ACCURATE. SEARCH ON THE AHRI REFERENCE # TO QUICKLY LOCATE THIS COMBINATION IN THE DIRECTORY.

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.: 131007151878121802

Certificate of Product Ratings

AHRI Certified Reference Number: 8778445

Date: 2/23/2016

Product: Variable Speed Multi-Split Heat Pump

Outdoor Unit Model Number: VOM0362H2RE509

Indoor Unit Type: Non-Ducted Indoor Units

Manufacturer: INNOVAIR CORPORATION

Trade/Brand name: INNOVAIR

Series name:

Manufacturer responsible for the rating of this system combination is INNOVAIR CORPORATION

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh): 53000

EER Rating (Cooling): 9.45

SEER Rating (Cooling): 16.00

Heating Capacity(Btuh) @ 47 F: 61500

Region IV HSPF Rating (Heating): 8.20

Heating Capacity(Btuh) @ 17 F: 43500

AHRI CERTIFIED®
www.ahridirectory.org

CERTIFIED RATINGS FOR VARIABLE-SPEED, MINI- AND MULTI-SPLIT SYSTEMS ARE VALID FOR ALL COMBINATIONS OF INDOOR UNITS (BASED ON COMBINATION TYPES) WITH THE SPECIFIC OUTDOOR UNIT LISTED ABOVE AND IN THE AHRI DIRECTORY OF CERTIFIED EQUIPMENT. VISIT WWW.AHRIDIRECTORY.ORG TO VERIFY THAT THIS COMBINATION IS AN ACTIVE LISTING AND THE DATA LISTED ON THIS CERTIFICATE IS ACCURATE. SEARCH ON THE AHRI REFERENCE # TO QUICKLY LOCATE THIS COMBINATION IN THE DIRECTORY.

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.: 131007152682821382